



Workers' Compensation Board of British Columbia

Corporate and Health Care Purchasing

ADDENDUM #2

*Invitation to Tender (ITT)
for*

Installation of Standby Generators and Parallel Switchboard

ITT #019-2009

Issue Date: May 7, 2009

***NEW* Tender Closing Date and Time:**

**2:00 PM – Pacific Time on
May 14, 2009**

Per WorkSafeBC Security/Corporate and Health Care Purchasing Time Clock
Bids received after the deadline may be rejected.

Bidders are requested to deliver and ensure bids are received and time/date stamped at:

Mail / Courier / By Hand:	Fax
<p>Worker and Employer Services – Main Entrance/Security Desk WorkSafeBC 6951 Westminster Highway Richmond, BC V7C 1C6 Attn: Corporate and Health Care Purchasing</p>	<p>Corporate and Health Care Purchasing Fax: (604) 276-3260 (24 hour availability) Maximum twenty (20) pages WorkSafeBC will NOT accept responsibility for a busy fax line, incomplete transmissions, etc.</p>
Electronically	
<p>Electronic copies of the ITT may be submitted in accordance with the BC Bid instructions for e-bidding. Only pre-authorized e-bidders registered on the BC Bid system will be able to submit electronic bids.</p>	
Email responses will NOT be accepted.	

ADDENDUM #2

WorkSafeBC is issuing this Addendum to all potential Bidders in response to questions asked at the site walk-through.

1.0 NUMBER OF TESTS BY GENERATOR SUPPLIER

Assume that there will be four separate testing and commissioning visits by the generator supplier, at which the electrical contractor is to be in attendance.

2.0 REMOVAL OF CRITICAL LOAD GENERATOR

If the electrical contractor requires a small section of ductwork on the north-east corner of room 7000, to be removed to allow the generator to pass on its way to the rooftop, then that ductwork will be removed and then reinstated by others.

3.0 DRAWING GIC-3

The electrical contractor shall assume that the 2 conductor shielded control wiring out of the paralleling and load sharing panel is #18AWG

4.0 DIVISION 0, SECTION 00100 - Instructions to Bidders, 4. Tender Closing and Delivery Instructions

- .1 The Closing Date for this Tender is **May 7, 2009 at 2:00 PM per WorkSafeBC Security/Corporate and Health Care Purchasing Time Clock (Pacific Time).**

REPLACE WITH:

- .1 The Closing Date for this Request for Tender is **May 14, 2009 at 2:00 PM per WorkSafeBC Security/Corporate and Health Care Purchasing Time Clock (Pacific Time).**

Addenda are the only means of verifying, clarifying or changing any of the information contained in this tender. Other than the Corporate and Health Care Purchasing, no employee or agent of WorkSafeBC is authorized to change the content of this tender and/or any addenda. Receipt of all addenda must be acknowledged in the space provided on the Bid Form.

Any questions related to the tender must be directed to the Purchasing Officer whose name appears below. The Bidders shall **NOT** contact or ask questions of the WorkSafeBC department for which the contracts being procured, unless so directed elsewhere in this document.

TENDER INQUIRIES:

Mercedita (Didit) Lachica, Purchasing Officer
Corporate and Health Care Purchasing
Phone #: (604) 276-3109
Fax #: (604) 276-3260
Email: purchase@worksafebc.com