



Workers' Compensation Board of British Columbia

Corporate and Health Care Purchasing

ADDENDUM #1

*Request for Quote (RFQ)
for*

LED Luminaires

RFQ #046-2009

Issue Date: October 21, 2009

Quotation Closing Date and Time:

**2:00 PM – Pacific Time on
October 30, 2009**

Per WorkSafeBC Security/Corporate and Health Care Purchasing Time Clock
Quote received after the deadline may be rejected.

Bidders are requested to deliver and ensure quotes are received and time/date stamped at:

Mail / Courier / By Hand:	Fax
<p>Worker and Employer Services – Main Entrance/Security Desk WorkSafeBC 6951 Westminster Highway Richmond, BC V7C 1C6 Attn: Corporate and Health Care Purchasing</p>	<p>Corporate and Health Care Purchasing Fax: (604) 276-3260 (24 hour availability) Maximum twenty (20) pages WorkSafeBC will NOT accept responsibility for a busy fax line, incomplete transmissions, etc.</p>
Electronically	
<p>Electronic copies of the RFQ may be submitted in accordance with the BC Bid instructions for e-bidding. Only pre-authorized e-bidders registered on the BC Bid system will be able to submit electronic bids.</p>	
Email responses will NOT be accepted.	

ADDENDUM #1

Questions and Answers

Q1: “What wattage bulbs are they replacing (power smart rebate)?”

A1: “The new LED luminaires will be used to replace existing 250W Mercury Vapour luminaires.”

Q2: “If we can’t get our foot candles that low will we be disqualified?”

A2: “We will review the photometric plot(s) and luminaire data submitted and determine if the lighting level and the uniformity is acceptable or not.”

Q3: “Is lumen or is foot candles more important?”

A3: “Foot candle lighting level and uniformity is more important. All bidders are required to state the lumen output of their proposed luminaire.”

Q4: “For our application we can custom your individual LED configurations for each spread to match exactly, as we represent a manufacturer in North America, so if you have more than just one drawing layout, we can build for each pole?”

A4: “The specification requires all luminaires to be CSA and UL certified, and requires that photometric plots be submitted to confirm lighting levels over a typical area. In order to produce the photometric plot(s), the luminaire needs to have an IES (Illuminating Engineering Society) file produced by a reputable laboratory testing agency. These requirements exclude the construction of a number of ‘custom’ luminaires. WorkSafeBC requires a standard product that can be replaced easily and quickly should the need arise.”

Clarifications

5. WorkSafeBC will require a copy of the IES file for the luminaire proposed. This file is used by the bidders to produce the required photometric plot(s) and therefore should be readily available.
6. WorkSafeBC will require the bidders to state which program was used to produce the photometric plot(s). Closing date of October 30, 2009 remains the same.

Addenda are the only means of verifying, clarifying or changing any of the information contained in this quotation. Other than the Corporate and Health Care Purchasing, no employee or agent of WorkSafeBC is authorized to change the content of this quotation and/or any addenda. Receipt of all addenda must be acknowledged in the space provided on the Bid Form.

Any questions related to the quotation must be directed to the Purchasing Officer whose name appears below. The Bidders shall **NOT** contact or ask questions of the WorkSafeBC department for which the contracts being procured, unless so directed elsewhere in this document.

QUOTATION INQUIRIES:

Todd Stojcic
Corporate and Health Care Purchasing
Phone #: (604) 279-7413
Fax #: (604) 276-3260
Email: purchase@worksafebc.com